

3.1.9 2003 Commercial Delivered Energy Consumption Intensities, by Principal Building Type and Vintage (1)

Consumption (kBtu/SF)				Consumption (kBtu/SF)			
Building Type	Pre-1959	1960-1989	1990-2003	Building Type	Pre-1959	1960-1989	1990-2003
Health Care	178.1	216.0	135.7	Education	77.7	88.3	80.6
Inpatient	230.3	255.3	253.8	Service	62.4	86.0	74.8
Outpatient	91.6	110.4	84.4	Food Service	145.2	290.1	361.2
Food Sales	205.8	197.6	198.3	Religious Worship	46.6	39.9	43.3
Lodging	88.2	111.5	88.1	Public Order & Safety	N.A.	101.3	110.6
Office	93.6	94.4	88.0	Warehouse & Storage	N.A.	38.9	33.3
Mercantile	80.4	91.8	94.4	Public Assembly	61.9	107.6	119.7
Retail (Non-Malls)	74.1	63.7	86.4	Vacant	21.4	23.1	N.A.
Retail (Malls)	N.A.	103.9	99.5	Other	161.3	204.9	125.3

Note(s): 1) See Table 3.1.3 for primary versus delivered energy consumption.

Source(s): EIA, 2003 Commercial Buildings Energy Consumption and Expenditures: Consumption and Expenditures Tables, Oct. 2006, Table C12a.